









Output Wiring Onboard 24VAC CO2 Burner



NOTE 1

RIB RELAY


10-30VAC
COMM

COIL

CO2 BURNER



DB01



GREY 19 CONNECTION 24VAC
DISTRIBUTION BLOCK (NEUTRAL)
LOCATED ON DIN RAIL IN
CONNECT CONTROLLER ENCLOSURE

NOTES:

1. ENSURE BLUE JUMPER IS INSTALLED.